



- 1. PLACE WEAKENED PLANE JOINTS AT 1/4 POINTS OR 20 FT. O.C. (MAX).
- 2. PORTLAND CEMENT CONCRETE SHALL BE 3,500 PSI, AS PER SECTION 90 OF THE CALTRANS STANDARD SPECIFICATIONS.
- 3. REINFORCEMENT SHALL BE GRADE 60, AS PER SECTION 52 OF THE CALTRANS STANDARD SPECIFICATIONS.
- 4. AGGREGATE BASE SHALL BE CLASS 2, AS PER SECTION 26
  OF THE CALTRANS STANDARD SPECIFICATIONS. COMPACT TO 95% RELATIVE COMPACTION AS PER ASTM D-1557.
- 5. THICKEN ALL ENDS AND OUTSIDE EDGES AND REINFORCE WITH A #6 REBAR AS SHOWN ABOVE.

No	Ву	Revision	CIT	EV OF CAN	DADLO		W. W. W.
			CITY OF SAN PABLO  ONE ALVARADO SQUARE, SAN PABLO, CA 94806 (510) 215-3030 FAX 215-3031				
Checked By:				BUS PAD			MUITIN
Approved By:					AND NOT	ES	STD DET SA-05
PUBLIC WORKS DIVISION MANAGER DATE					N	O SCALE	SHEET 2 OF 2